



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznámený subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Notified Body 1020
Branch 0700 – Ostrava

REPORT

on the assessment of performance

according to the Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011
(the Construction Products Regulation or CPR), Art. 1.4 of the Annex V (system 3)

No. 1020-CPR-070059217

Trade name:

Fibre-cement flat sheets NT-FS-A5 3050 x 1220 x 8 (& so on)

Manufacturer:

LTD IVANO-FRANKIVSK-DAH

INo: 43632293

Address: 77422, Ivano-Frankivsk region, Tysmenytsia district,
v. Yamnytsia, N. Yaremchuk st., apt. 2/1, Ukraine

Plant: LTD IVANO-FRANKIVSK-DAH

Address: 77422, Ivano-Frankivsk region, Tysmenytsia district,
v. Yamnytsia, N. Yaremchuk st., apt. 2/1, Ukraine

Order: Z070200219

Number of report pages including title-page: 3

Number of Annexes: 3

The person taking responsibility for the content of this report:

Vladimír Plaček Ph.D.
Head Assessor

The person taking responsibility for the correctness of this report:

Stamp of the Notified Body 1020

Ostrava, 6 April 2021



Vojtěch Šebek
Deputy Manager of the Notified Body 1020

Note: This Report may not be reproduced otherwise but complete without a written consent of the Notified Body Deputy Manager.
Technical and Test Institute for Construction Prague, Branch 0700-Ostrava, U Studia 278/14, 700 30 Ostrava, Czech Republic
Tel.: 595 707 201, Internat.: +420 595 707 201, e-mail: sebek@tzus.cz, www.tzus.cz, Bank Name: ČSOB. a.s., branch office, Praha 1,
Jindřišská 2, Czech Republic, Account Number: 579195563/0300, INo: 000 15679, VAT: CZ00015679

1. Specification of tested subject

Description and intended use of the product: Fibre cement flat sheets for internal wall and ceiling finishes, external wall and ceiling finishes.

Technical specification: EN 12467:2012+A2:2018

Manufacturer: LTD IVANO-FRANKIVSK-DAH

INo: 43632293

77422, Ivano-Frankivsk region, Tysmenytsia district, v. Yamnytsia, N.
Yaremchuk st., apt. 2/1, Ukraine

Plant: LTD IVANO-FRANKIVSK-DAH

INo: 43632293

77422, Ivano-Frankivsk region, Tysmenytsia district, v. Yamnytsia, N.
Yaremchuk st., apt. 2/1, Ukraine

2. Sampling

Date of sampling: 23/10/2020

Place of sampling: LTD IVANO-FRANKIVSK-DAH

Sampler: LTD IVANO-FRANKIVSK-DAH

Sampling method: no verified data

Transport mode: delivery service

Date of the taking over: 16/11/2020

Sample Registration number: VZ070210120

3. The assessment of performance on basis of testing, calculation, tabulated values, descriptive documentation

The assessment was carried out on basis of testing.



3.1 The assessment on basis of testing

3.1.1 Reaction to fire

Sample specification: part of PK1-01-21-008-E-0 issued on 05/02/2021.

Assessment according to the test method: EN 13501-1:2018.

Test was carried out by: PAVUS, a.s.

Date of the test ending: PK1-01-21-008-E-0 issued on 05/02/2021.

Another date about the test: not applicable.

Test result:

Characteristic	Obtained data value
	Sample No. VZ070210120
Reaction to fire class	A1, A1 _{fl}

3.1.2 Dangerous substances content

Product is produced with non-asbestos technology according to material safety data sheet provided by manufacturer.

4. Annexes

4.1 Annex 1

Reaction to fire classification report PK1-01-21-008-E-0 issued on 05/02/2021 by PAVÚS, a.s., Czech Republic (3 pages)

